

C-1

P902

WELL COMPLETION REPORT  
3/71

CROTON FALLS

PUTNAM COUNTY DEPARTMENT OF HEALTH  
Division of Environmental Health Services  
COUNTY OFFICE BUILDING - CARMEL, NEW YORK

This report is to be completed by well driller and submitted to County Health Department together with laboratory report of analysis of water sample indicating water is of satisfactory bacterial quality before certificate of construction compliance is issued.

REPORT MUST BE SUBMITTED WITHIN 30 DAYS OF WELL COMPLETION

OWNER	NAME JOHN KROLL		ADDRESS TEA KETTLE RD. MAHOPAC, N.Y.	
LOCATION OF WELL	(No. & Street) TEA KETTLE RD.		(Town) MAHOPAC	(Lot Number) 10
PROPOSED USE OF WELL	<input checked="" type="checkbox"/> DOMESTIC <input type="checkbox"/> BUSINESS ESTABLISHMENT <input type="checkbox"/> FARM <input type="checkbox"/> TEST WELL <input type="checkbox"/> PUBLIC SUPPLY <input type="checkbox"/> INDUSTRIAL <input type="checkbox"/> AIR CONDITIONING <input type="checkbox"/> OTHER (Specify)			
DRILLING EQUIPMENT	<input type="checkbox"/> ROTARY <input checked="" type="checkbox"/> COMPRESSED AIR PERCUSSION <input type="checkbox"/> CABLE PERCUSSION <input type="checkbox"/> OTHER (Specify)			
CASING DETAILS	LENGTH (feet) 30'	DIAMETER (inches) 6"	WEIGHT PER FOOT 17 $\frac{1}{2}$	<input checked="" type="checkbox"/> THREADED <input type="checkbox"/> WELDED DRIVE SHOE <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO    WAS CASING ORCUTED? <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO
YIELD TEST	<input type="checkbox"/> BAILED <input type="checkbox"/> PUMPED <input checked="" type="checkbox"/> COMPRESSED AIR	HOURS 6		G.P.M. 5 G.P.M. YIELD (G.P.M.) 5 G.P.M.
WATER LEVEL	MEASURE FROM LAND SURFACE—STATIC (Specify feet) 20'		DURING YIELD TEST (feet) 405' Depth of Completed Well in feet below Land surface: 405'	
SCREEN DETAILS	MAKE NONE			LENGTH OPEN TO AQUIFER (feet) NONE
	SLOT SIZE NONE	DIAMETER (inches) NONE	IF GRAVEL PACKED: Diameter of well including gravel pack (inches):	GRAVEL SIZE (inches) NONE FROM (feet) NONE TO (feet) NONE

DEPTH FROM LAND SURFACE		FORMATION DESCRIPTION
FEET	to FEET	
0	6	GRAVEL.
6	21	LIGHT GREY ROCK.
21	405	LIGHT AND DARK GREY ROCK.

Sketch exact location of well with distances, to at least two permanent landmarks.

WELL IS EXPOSED 18" ABOVE GRADE.

If yield was tested at different depths during drilling, list below	
FEET	GALLONS PER MINUTE

DATE WELL COMPLETED 5/31/77	DATE OF REPORT 6/1/77	WELL DRILLER (Signature) Bruce W. Wragg
--------------------------------	--------------------------	--